

Addendum No. 3 to IFB 14-14



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: Prospective bidders IFB 14-14, Somerville High School Partial Roof Replacement

From: Orazio DeLuca, Contract Manager

Date: August 5, 2013

Re: New Project Specifications

Addendum No. 3 to IFB 14-14

The City is issuing this addendum to IFB 14-14, Somerville High School Partial Roof Replacement to issue the new updated specifications for the roofing project.

Changes to the specifications:

Part 1 – Table of Contents:

A Replace "003000 – Form for General Bid" with "003050 – Form for General Bid"

Part 1 – Section 3:

A Add 003000: Form for Sub-Bid for Construction Contract:

Part 1 - Section 3, pages 25-38:

A Replace footer "Acknowledgement of Notice to Bidders" with "Responsible Employer Ordinance".

B Replace footer "003300" with "003250"

Section 003050 – Form for General Bid:

A Delete this form entirely and replace with the revised form provided under this addendum.

Section 07500 – Polyvinyl – Chloride (PVC) Roofing:

Addendum No. 3 to IFB 14-14

A Delete this specification section entirely and replace with the revised specification section provided under this addendum.

Section 07620 – Sheet Metal Flashing, Paragraph 2.6 Item A:

A Replace sub-item a "Aluminum: .050 inch thick." with "Roofing manufacturer's standard PVC clad galvanized metal."

Changes to the Drawings:

Sheet 101 – General Notes:

- A Note #4: Delete in its entirety. Replace with "Not Used"
- B Note #5: Replace "R-30" with "R-24"

Attachments:

003050 General Bid Form

003000 Form for Sub-Bid for Construction Contract

007500 - Polyvinyl – Chloride (PVC) Roofing

Prevailing Wage Statement of Compliance

Questions:

Question: The Quality Requirement Form (Section 00335) is not in the bid package but it is in Section 002000-7?

Answer: Yes, the Quality Requirement Form can be Found on page 7 of Section 00200 - Instructions to Bidders.

Addendum 2-

Question 1-Regarding IFB 14-14: Is there a Form for Filed Sub-Bids? I don't see one as part of the Bid Submission Documents. I only see the Form for General Bid.

Answer 1- Make a copy of the form for General Bid, use the same form and label it Sub-Bid.

Question 2-we are certified by the DCAMM as a General Bidder in Roofing (as well as a Sub-Bidder). Is a DCAMM cert in Roofing not enough to submit a bid as a General Bidder?

Answer 2- DCAMM certification in Roofing and General Biddser will be accepted for this project.

Question 3-Are there any filed sub bids for this project?

Addendum No. 3 to IFB 14-14

Answer 3- YES. The filed sub bids are listed in the bid package, Thermal & Moisture Protection: Roofing (Filed Sub Bid Required), Polyvinyl-Chloride (PVC), Sheet Metal Flashing and Trim

Question 4- As a filed sub bid submitting our bid on the General Bid form, is our bid due on August 7 or August 14th? Also, if we are a filed sub bidder, are we only bidding the 3 sections designated for filed sub bid, or are we bidding everything?

Answer 4- The due date for filed sub bids is August 7 and General bids are due on August 14. Filed sub bidders should be bidding on the 3 sections designated as sub bids.

Addendum 1

- **Filed Sub-bids are due on August 7, 2013 @ 11:30AM**
- **General Bids are due on August 14, 2013 @ 11:30AM**

PLEASE BE SURE TO ACKNOWLEDGE ALL ADDENDA ON THE BID PRICING SHEET

Thank you-
Orazio P. DeLuca
Contract Manager
Purchasing Department
City of Somerville
617-625-6600 x 3407